

PROPANE GAS TANKS ALLOWED VS. NOT ALLOWED

State of Florida and the North Collier Fire district prohibit the storage of any propane tank greater than 2.7lbs inside a multi-family dwelling, including inside a garage. Your coach home buildings are considered multi-family dwellings since each building has 4 residential units. Attached you will find the North Collier County Grill regulations and Deceleration Section 12.17 below for Outdoor Cooking.

12.17 Outdoor Cooking. Built-in electric grills may be used on balconies and lanais provided they comply with the local county and fire codes and the Association's Rules and Regulations. Gas and charcoal grills when in use must be on brick paver parking pad at least ten (10) feet from the building. Gas grills cannot have a propane gas tank larger than a two point seven (2.7) pound canister and the maximum number of 2.7 pound canisters that can be stored inside the garage is two (2). Grills must be completely cooled off prior to storage, and can only be stored in the garage. Charcoal grills must be cooled off and emptied of all embers and residue prior to storage in garage.

NOT ALLOWED

**TYPICAL GAS TANK
FOR LARGE GRILLS**



ALLOWED

**SMALL TANK FOR
SMALLER/CAMP GRILLS**

